

**Before**

**UTTARAKHAND ELECTRICITY REGULATORY COMMISSION**

**In the matter of:**

Application seeking approval of releasing additional 6 MVA load (Total of 20 MVA) on Supply Voltage of 33 kV to M/s Birla Tyres, Unit-2, Hardwar.

**And**

**In the matter of:**

M/s Birla Tyres, Unit-II, Khedi Mubarakpur, Laksar, Haridwar ....Petitioner

**&**

1. Uttarakhand Power Corporation Limited (UPCL) .... Respondent 1
2. Power Transmission Corporation of Uttarakhand Limited (PTCUL) .... Respondent 2

**Coram**

**Shri C.S. Sharma**

**Member-Chairman**

**Shri K.P. Singh**

**Member**

**Date of Hearing: May 05, 2014**

**Date of Order: May 05, 2014**

Heard the Petitioner and Respondents in the matter.

It is ordered that:

1. The Commission allows now release of 4 MVA load in addition to the contracted load of 14 MVA (Now Total 18 MVA) from the existing 33 kV line supplying to the consumer till completion of the pending 132 kV works and directs Respondent No. 1 namely- UPCL to conduct a meeting with the Petitioner within 15 days from the date of this Order and chalk out an Action Plan for carrying out the required modifications in the existing 33 kV line/system for releasing additional load of 02 MVA through this 33 kV line considering the compliances of safety rules and submit a report to the Commission latest by 26.05.2014.

2. Respondent No. 2 namely- PTCUL should submit:

- (1) The legal authority under which it started constructing the said transmission line.
- (2) The copies of the permissions procured for constructing the said transmission line.
- (3) The copies of the Orders issued in the matter from various Courts from time to time.

Ordered Accordingly.

**(K.P. Singh)**  
**Member**

**(C.S. Sharma)**  
**Member-Chairman**