

Before

UTTARAKHAND ELECTRICITY REGULATORY COMMISSION

In the matter of:

Misc. App. No. 02 of 2015

- 1) Investment Approval for construction of 1. (2x25 MVA), 220/33 kV S/s Barham (Jauljivi) and 2. Construction of LILO line of one circuit 220 kV Dhauliganga-Pithoragarh (PGCIL) line at proposed (2x25 MVA), 220/33 kV S/s Barham (Jauljivi)

Misc. App. No. 03 of 2015

- 2) Investment approval for increasing capacity of 132/33 kV S/s Jwalapur from 2x40 MVA to 3x40 MVA.

Power Transmission Corporation of Uttarakhand Ltd. (PTCUL).

...Petitioner

CORAM

Shri Subhash Kumar	Chairman
Shri C.S. Sharma	Member
Shri K.P. Singh	Member

Date of Hearing: February 04, 2015

Date of Order: February 06, 2015

Heard the Petitioner on the above 02 matters. The Commission directs to admit Misc. App. No. 3 of 2015 pertaining to investment approval for Augmentation of 132/33 kV Sub-station Jwalapur from 2x40 MVA to 3x40 MVA.

For Misc App. No. 2 of 2015 pertaining to investment approval for construction of (2x25 MVA), 220/33 kV S/s Barham (Jauljivi) and construction of LILO line of one circuit 220 kV Dhauliganga-Pithoragarh (PGCIL) line at proposed (2x25 MVA), 220/33 kV S/s Barham (Jauljivi), the Commission has directed that since the Petitioner has failed to submit approval

from Ministry of Environment and Forest, GoI for allotment of forest land for construction of LILO line and also the proof for allotment of land for construction of Substation, the aforesaid application may not be admitted.

The Commission further directs the Petitioner to again approach the Commission for the approval of the said works once the land for the substation and line are transferred in the name of the Petitioner. While doing so, the Petitioner should also give proper justification for going for the higher cost option of GIS Substation.

Ordered Accordingly.

(K.P. Singh)
Member

(C.S. Sharma)
Member

(Subhash Kumar)
Chairman