

Before

UTTARAKHAND ELECTRICITY REGULATORY COMMISSION

In the matter of:

Grid connectivity for 12.6 MW SHP of M/s Uttar Bharat Hydro Power Pvt. Ltd., New Delhi (Suo-moto).

And

In the matter of:

Uttarakhand Power Corporation Limited (UPCL)

...Respondent 1

M/s Uttar Bharat Hydro Power Pvt. Ltd.

....Respondent 2

Coram

Shri Subhash Kumar Chairman

Shri C.S. Sharma Member

Date of Hearing: July 02, 2015

Date of Order: July 02, 2015

Heard the Respondents in the matter.

1. Respondent No. 2 informed that its plant is ready to be commissioned by July end. Hence, to avoid bottling up of the generation the Commission, ad-interim, allows Respondent No. 2 Loop In Loop Out (LILO) connection from 33 kV Kapkote-Karmi Transmission line and directs Respondent No. 1 to provide the same.
2. Respondent No. 1 submitted that in its PPA dated 16.12.2002, Respondent No. 2 agreed for construction of evacuation line from its generating station to Kapkote substation. Representative of Respondent No. 2 also informed that the construction of the generating station started in 2008 and in February 2015, it informed Respondent No. 1 that it would not be able to construct the line till Kapkote. Respondent No. 2 is directed to submit the details of steps taken by it in this regard from 2008 to 2015 latest by 20.07.2015.
3. Further, the Respondent No. 1 is directed to submit following information latest by 20.07.2015:-

- (1) The details of existing power evacuation capacity at Kapkote S/s and its adequacy with respect to evacuation of the available generation in the Kapkote region.
- (2) Submit details of upcoming generation capacity in Kapkote region (Bageshwar district) in next 5 years and the comprehensive plan for power evacuation for the same.

Ordered Accordingly.

(C.S. Sharma)
Member

(Subhash Kumar)
Chairman