

Before

UTTARAKHAND ELECTRICITY REGULATORY COMMISSION

Misc. Appl. No. 63 of 2015

In the matter of:

System strengthening of 132 kV S/s Kichha Comprising of:

- a. Augmentation of 132/33 kV transformer capacity at 132 kV S/s Kichha from 2x40 MVA to 3x40 MVA including construction of associated 01 no. 132 kV bay and 01 no. 33 kV bay and bisection of 33 kV main bus.
- b. Construction of 01 no. Bus Coupler bay using hybrid switchgear and bisection of existing 132 kV main bus.
- c. Proposal for ampacity increment of 132 kV Pantnagar-Rudrapur circuit (7.6 Kms.) by replacing for existing ACSR Panther conductor with high capacity ACCC Casablanca conductor.

And

In the matter of:

Power Transmission Corporation of Uttarakhand Limited (PTCUL)Petitioner
Vidyut Bhawan, Near ISBT Crossing, Saharanpur Road,
Majra, Dehradun

CORAM

Shri Subhash Kumar	Chairman
Shri K.P. Singh	Member

Date of Hearing: November 17, 2015

Date of Order: November 17, 2015

Heard the Petitioner in the matter for admissibility.

The Petition is hereby admitted.

(K.P. Singh)
Member

(Subhash Kumar)
Chairman