

**Before**

## **UTTARAKHAND ELECTRICITY REGULATORY COMMISSION**

**In the matter of:**

Petition on Relaxation in RE Regulations, 2013 in respect to Sarju-II & Sarju-III SHPs of M/s UBHP Ltd. for restriction of any claim under deemed generation on account of the restraint in evacuation system caused due to allowance of evacuation of power from Sarju-II SHP, till the under constructed 33 kV line between Bageshwar and Kapkote on panther conductor is completed.

**In the matter of:**

Uttarakhand Power Corporation Ltd.

... Petitioner

**AND**

**In the matter of:**

M/s Uttar Bharat Hydro Power (P) Ltd.

... Respondent

**CORAM**

**Shri Subhash Kumar Chairman**

**Shri K.P. Singh Member**

**Date of Hearing: August 9, 2016**

**Date of Order: August 9, 2016**

Heard the Petitioner and the Respondent in the matter. Ordered that the Petition be admitted. The Commission further directs District Magistrate, Bageshwar to form a Committee headed by him and comprising of the representatives of both UPCL as well as the Generator (M/s Uttar Bharat Hydro Power Pvt. Ltd.) and submit the status alongwith schedule date of completion of each of the following works within 15 days from the date of Order after holding a proper meeting of the aforesaid Committee constituted in the matter:

- (a) On going works carried out by UPCL including replacement of Racoon conductor by Dog Conductor between its existing 33 kV S/s at Kapkote and the 33 kV S/s at Bageshwar.
- (b) Construction of 33 kV additional line on panther conductor between existing 33 kV Kapkote S/s and 33 kV Bageshwar S/s.
- (c) Construction of dedicated line by the Generator (M/s Uttar Bharat Hydro Power Pvt. Ltd.) from its Sarju-II generating station and upto UPCL's 33 kV S/s at Kapkote.

Ordered accordingly.

**(K.P. Singh)**  
**Member**

**(Subhash Kumar)**  
**Chairman**