

# UTTARAKHAND ELECTRICITY REGULATORY COMMISSION

## ORDER

The Commission has noticed that UPCL is overdrawing power from grid even at times when grid frequency is very low. As per Regulation 4.4.2(1) of the State Grid Code, UPCL is required to restrict the net drawal from the grid to within its drawal schedules whenever the system frequency is below 49.5 Hz. UPCL is, therefore, directed to ensure that no overdrawal is done whenever system frequency is below 49.5 Hz and for doing so it may resort to emergency load shedding on rotational basis without any discrimination.

**V.K. Khanna**  
**Member**

**V.J. Talwar**  
**Chairman**

Dated: 29<sup>th</sup> March, 2008